

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20190719-E334998  
**Report Reference** E334998-20190626  
**Issue Date** 2019-JULY-19

**Issued to:** ELOBAU GMBH & CO KG  
Zeppelinstrasse 44  
88299 Leutkirch GERMANY

**This certificate confirms that  
representative samples of**

AUXILIARY DEVICES  
USL, CNL: Open-type Auxiliary Device, model 4621273E.

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL508 & CSA C22.2 No. 14-18 - Industrial Control  
Equipment

**Additional Information:** See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up  
Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's  
Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations>.

