



Product Service

CERTIFICATE

No. Z10 16 06 20166 040

Holder of Certificate: **elobau GmbH & Co. KG**Zeppelinstr. 44
88299 Leutkirch
GERMANY

Factory(ies):

24820

Certification Mark:



Product:

**Safety-Related Programmable Systems
Modular Safety Integrated Controller**

Model(s):

eloProg

Parameters:

Rated voltage: 24VDC \pm 20%
Operating temperature: -10...55°C
Storage temperature: -20...85°C
Max. rating relay output: 230 VAC - 6A

The report and the user documentation in the current valid revision are mandatory part of this certificate. The product complies with the following safety requirements only if the specifications documented in the currently valid revision of this report are met. The certified components are listed in report EL86610C in the current valid revision.

Tested
according to:2006/42/EC
EN 61131-2:2007
EN ISO 13849-1:2008 (Cat 4, PL e)
EN 61496-1:2013 (Type 4)
EN 61508-1:2010 (SIL3)
EN 61508-2:2010 (SIL3)
EN 61508-3:2010 (SIL3)
EN 61508-4:2010 (SIL3)
IEC 61784-3(ed.1)
EN 62061:2005 (SIL CL3)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.:

EL86610C

Valid until:

2019-06-15

Date, 2016-06-17

(Peter Weiss)

Page 1 of 1

